

NOTES:

1. X1 - DENOTES ENDEAVOUR ENERGY INTERFACE TERMINAL BLOCK. TERMINAL BLOCKS ARE SHOWN INDICATIVELY AND MAY CHANGE DURING ENDEAVOUR ENERGY APPROVAL PROCESS OF MANUFACTURER EQUIPMENT DRAWINGS.
2. TERMINAL BLOCK ALLOCATION
X11 - X18 AC SUPPLY SUITABLE FOR 10mm WIRES (WDU10)
X1-300 - X1:349 : TRF TRIP
X1-350 - X1:499: SCADA
3. AC TERMINAL BLOCKS ARE TO BE CLEARLY LABELLED WITH RED LABELS 'WARNING 240V AC, SHROUDED AND SEGREGATED FROM THE REST OF THE TERMINAL BLOCKS VIA DIVIDERS.
4. ANY ADDITIONAL MANUFACTURER SCADA ALARMS ARE TO BE TERMINATED AS REQUIRED.
5. PROTECTION CIRCUIT TERMINALS SHALL BE SPRING LOADED TERMINALS.
6. LV & HV PROTECTION CTs MAY BE REQUIRED IN AUTO TRANSFORMERS. CT TERMINALS SHALL BE SPRING LOADED AND ONLY BE PROVIDED FOR INSTALLED CT ONLY.

TERMINAL SYMBOLS

- (WTR2.5)  Link Terminal
(WDU6-SL)  Spring Terminal
(WTL6/4)  Slide Link Terminal
EARTH 

