






NOTES

- 1. This drawing is to be used in conjunction with ETS 0077
- 2. "Danger High Voltage" sign and other signs to be fitted on all doors as shown
- 3. Substation numbers to be fitted by transformer workshop staff prior to issue
- 4. All doors and door stiffeners 1.5mm 304 S/S 2B and other parts 2mm 304 S/S
- 5. The paint finish shall be primed to powder coated "Avocado Green" (Code G34) TO AS2700.





SECTION C-C


EARTH STRAP 70mm² CONNECTING DOOR TO CABINET ENCLOSURE (TYPICAL)



SECTION D-D



© This drawing and the copyright therein is the property of Endeavour Energy and may not be copied, reproduced, distributed, loaned or used without the written consent of Endeavour Energy.



DO NOT SCALE DIMENSIONS IN MILLIMETRES

REFERENCE DRAWINGS

ORIGINAL SCALE APPROVED G.Ford



AUTHORISED J. Pereira

DRAWN P Watson

SIZE 10 - PADMOUNT SUBSTATION STAINLESS STEEL CUBICLE HV AND LV COMPARTMENTS

MGR NETWORK ENGINEERING 08-12-11

DATE 26 May 2011

CHD

360392 A

AMENDMENTS ORIGINAL ISSUE A

J R No.

SHEET No 1 OF 1 SHEETS