














AMENDMENTS		
A	ORIGINAL ISSUE	
B	DR'N	FM
	CH'D	
	DATE	8.7.98
	JR No	- -
	REDRAWN FROM DWG 249019	
C	DR'N	VZ
	CH'D	
	DATE	22.12.08
	JR No	- -
	TITLE BLOCK AND MINOR CHANGES	
D	DR'N	BTB
	CH'D	D.H.
	DATE	12.4.2010
	JR No	- -
	TITLE BLOCK AND MINOR CHANGES	
	M.A.E.	I.P.

ALLOWABLE COMBINATIONS:

IMPACT ABSORBING COLUMNS WITH CURVED PIPE OUTREACHES FOR MAJOR ROADS

COLUMN 1.	2.	3.	4.	5.	6.	7.
OUTREACHES & EXTENSION / POLES	3m OUTREACH Stock Ref. 1540210	4.5m OUTREACH Stock Ref. 1540228	6.0M OUTREACH AS COLUMN 3 + 1.5m EXTENSION Stock Ref. 1540236	2m POST TOP EXTENSION WITH 76mm O.D. SPIGOT Stock Ref. 1542265	DOUBLE 3m OUTREACH Stock Ref. 1542257	DOUBLE 4.5m OUTREACH AS COLUMN 6 + 2x1.5m EXTENSIONS Stock Ref. 1540236
	CAT No. IE3.0PCS	CAT No. IE4.5PCS	CAT No. IE1.5EXT	CAT No. IE2.00PTE	CAT No. IE3.0CPD	CAT No. IE1.5EXT(X2)
7.0m POLE Stock Ref. 1540178 CAT No. IE7.01A						
8.5m POLE Stock Ref. 1540186 CAT No. IE8.5IA						
10.0m POLE Stock Ref. 1540194 CAT No. IE10.01A						
11.5m POLE Stock Ref. 1540202 CAT No. IE11.5IA	 RESTRICTED USE	RESTRICTED USE	DO NOT USE THIS COMBINATION	RESTRICTED USE	DO NOT USE THIS COMBINATION	DO NOT USE THIS COMBINATION

NOTES:

1. Y Bracket IE/Y90AD, parallel Y barcket IE/YPAD & 45 degree adaptor IE/45WAD can be used on the combinations shown in columns 2,3 and 6 only.
2. 2 way adaptor IE/2WAD 3 way adaptor IE/3WAD may be used on the combinations shown in column 5 only.

©This drawing and the copyright therein is the property of Endeavour Energy and may not be copied, reproduced, distributed, leased or used without the written consent of Endeavour Energy.

Endeavour Energy

ORIGINAL SCALE	APPROVED BH
DRAWN	PW
DATE	3.4.01
CH'D	PA

REFERENCE DRAWINGS

DO NOT SCALE DIMENSIONS IN MILLIMETRES

AUTHORISED W. ISLEY

MANAGER DISTRIBUTION ENGINEERING 3.4.01

IMPACT ABSORBING COLUMN WITH CURVED PIPE OUTREACHES FOR MAJOR ROADS ALLOWABLE COMBINATIONS

A4 262836 D

SHEET No 1 OF 1 SHEETS