


AMENDMENTS	
A	ORIGINAL ISSUE
B	DRW: BJB EVD: D.H. DATE: 12.4.2010 JR No: - - REDRAWN: - - TITLE MODIFIED: - - M.A.E.: J.P.

NOTES:

1. ALL STEEL PLATES TO CONFORM TO AS 3678 GRADE 250 U.O.N.
2. ALL STEEL PIPES TO CONFORM TO AS 1163 GRADE 250 U.O.N.
3. ALL FILLET WELDS TO BE 6mm CONTINUOUS U.O.N. AND ARE TO CONFORM TO AS1554, PART 1, CATEGORY G.P. U.O.N
4. ALL SHARP EDGES AND BURRS TO BE REMOVED.
5. ALL STEEL TO BE FULLY HOT DIP GALVANIZED AFTER FABRICATION IN ACCORDANCE WITH AS/NZ4680.



PART No. IE/PT25AD

		THIS DRAWING AND THE COPYRIGHT HEREIN IS THE PROPERTY OF Endeavour Energy and may not be copied, reproduced, distributed, loaned or used without the written consent of Endeavour Energy.				DO NOT SCALE DIMENSIONS IN MILLIMETRES		REFERENCE DRAWINGS		AUTHORISED W. Isley			
 ORIGINAL SCALE		APPROVED S.Turki		POST TOP ADAPTOR 25 NB SPIGOT GENERAL DETAIL		DO NOT SCALE DIMENSIONS IN MILLIMETRES		MANAGER ASSET ENGINEERING		17.4.2009			
DRAWN VOJTECH		-										-	
DATE 17.3.09		-										-	
EVD B.Harrigan		-										-	
								A 4		333232		B	
										SHEET No 1 OF 1 SHEETS			