

IE 3.0 CPS
To suit 65 NB. spigot.
Material No – 1000004911



DETAIL A.
NTS.



IE 3.0 CPD
To suit 65 NB. spigot.
Material No – 1000004926



IE 4.5 CPS
To suit 65 NB. spigot.
Material No – 1000004912



DETAIL B.
NTS.



Suppied with M6 x 60 lg. hex. head screws.
and M6 nyloc nut with plain & spring washers.

1.5m. extension.
IE 1.5 EXT
To suit 32 NB. spigot.
Material No – 1000004913



NTS.

2.0m. post top extension.
IE 2.0 PTE
Material No – 1000004927



SECTION A–A
(2 PLACES)
NTS.

6 off M16 x 35 long
stainless steel screw c/w
M16 nut and lock nut

NOTES:

1. ALL STEEL PLATES TO CONFORM TO AS 3678 GRADE 250 U.O.N.
2. ALL STEEL BARS AND SECTIONS TO CONFORM TO AS 3679 GRADE 250 U.O.N.
3. ALL FILLET WELDS TO BE 6mm CONTINUOUS U.O.N. AND ARE TO CONFORM TO AS1554, PART 1, CATEGORY G.P. U.O.N
4. ALL SHARP EDGES AND BURRS TO BE REMOVED.
5. ALL TAPER LOCK JOINT LENGTHS ARE NOMINAL U.O.N.
6. ALL STEEL TO BE FULLY HOT DIP GALVANIZED AFTER FABRICATION IN ACCORDANCE WITH AS1650.

AMENDMENTS

A	ORGINALS ISSUE	PW	18/04/01
B	MINIMUM SIZES ADDED	BJH	1/3/04
C	STOCKCODE ADDED	LTB	21/5/08
D	DETAIL B CHANGED	JP	28/01/14
E	DR'N S.F CH'D E.W DATE 06/12/24 UR NoN/A REPLACED STOCK CODE BY MATERIAL NO UPDATE TITLEBLOCK	EDM	K.S

©This drawing and the copyright therein is the property of Endeavour Energy and may not be copied, reproduced, distributed, loaned or used without the written consent of Endeavour Energy.

ORIGINAL SCALE

APPROVED BH

DRAWN	PW		
DATE	18.4.01		
CH'D	PA		

Endeavour Energy

REFERENCE DRAWINGS

DO NOT SCALE
DIMENSIONS IN MILLIMETRES

AUTHORISED
W. ISLEY
MANAGER DISTRIBUTION ENGINEERING 18.4.01

MAJOR ROAD OUTREACHES
STANDARD SERIES
GENERAL ARRANGEMENT
PUBLIC LIGHTING

A3 262718 E

SHEET No 1 OF 1 SHEETS