


AMENDMENTS	
A	ORIGINAL
ISSUE	
REV	8/1/8
DATE	9/8/10
BY	---
CHKD	---
DATE	9/8/10
BY	---
CHKD	---
NEW CIRCUIT AND IMPROVED FRAME ADDED TO SHEET.	
MAE	LP

S.L Control point



--- LAY AC 16mm sq XLPE/PVC CABLES FULLY DUCTED
IN 50mm HD DUCT R.L. = XXXXm C.L. = XXXXm

ⓐ/ⓑ/ⓒ DENOTES PHASE

FINAL S.L. CIRCUIT

NOT TO SCALE

		Endeavour Energy	
ORIGINAL SCALE	APPROVED BH	TYPICAL STREETLIGHT CONTROL CIRCUIT ELECTRICAL DIAGRAM	
DATE	24/3/14	DID NOT SCALE	
CHKD	BH	DIMENSIONS IN MILLIMETRES	
300MM		REFERENCE DRAWINGS	
BH		W. ISLEY	
A4		NUMBER ATTACHED DRAWING	
287040		24/3/14	
B		SHEET No 1 OF 2 SHEETS	