AMENDMENTS	
A	ORIGINAL ISSUE
B	DR'N BIB; CH'D D.H.; DATE 12.4.2010; JR No - -
	CHANGES TO DRAWING FRAME
C	M.A.E. I.P.; DR'N BIB; CH'D D.H.; DATE 28.9.2010; JR No - -
	CHANGES TO DRAWING TITLE
D	M.A.E. I.P.; DR'N S.F; CH'D E.W; DATE 27-11-24; JR No N/A
	TITLE BLOCK & MATERIAL No. UPDATED. NOTE 1 DELETED
EDM	K.S

NOTES:

1. CONCRETE MIN . COMP STRENGTH 20MPa
2. INSTALL 50mm DIAMETER CONDUIT AS REQUIRED. USE LARGE RADIUS BENDS.



TYPE 3 RAGBOLT ASSEMBLY MATERIAL NO. 1000008031

© This drawing and the copyright therein is the property of Endeavour Energy and may not be copied, reproduced, distributed, loaned or used without the written consent of Endeavour Energy.

ORIGINAL SCALE

APPROVED BH

Endeavour Energy

REFERENCE DRAWINGS

DO NOT SCALE
DIMENSIONS IN MILLIMETRES

AUTHORISED W. ISLEY
MANAGER DISTRIBUTION ENGINEERING 29.6.01

DRAWN	PW
DATE	29.6.01
CH'D	PA

VEHICLE IMPACT PROTECTION FOUNDATION GENERAL DETAIL

A4 297512 D

SHEET No 1 OF 1 SHEETS