





AMENDMENTS	
A	ORIGINAL ISSUE


- NOTES:
1. ALL STEEL PLATES TO CONFORM TO AS 3678 GRADE 250 U.O.N.
 2. ALL STEEL BARS AND SECTIONS TO CONFORM TO AS 3679 GRADE 250 U.O.N. TO AS 1554, PART 1, CATEGORY G.P. U.O.N.
 3. ALL STEEL PIPES TO CONFORM TO AS 1163 GRADE 250 U.NO.
 4. ALL FILLET WELDS TO BE 6mm CONTINUOUS U.O.N. AND ARE TO CONFORM TO AS 1554, PART 1, CATEGORY G.P. U.NO.
 5. ALL SHARP EDGES AND BURS TO BE REMOVED.
 6. ALL STEEL TO BE FULLY HOT DIP GALVANIZED AFTER FABRICATION IN ACCORDANCE WITH AS 4680.
 7. SECTIONS TO BE STAGGERED DURING ASSEMBLY TO PREVENT SEAM WELDS LINING UP.




DETAIL A




OUTREACH DETAIL.




DETAIL D



SECTION A-A



DETAIL C



DETAIL B

COLUMN		'H'	'A'	'B'	'C'	'D'
WESTERLY	5.0	5000	6544			
WESTERLY	6.0	6000	7544			
WESTERLY	7.5	7500	9044			
WESTERLY	9.0	9000	10544			
WESTERLY	10.5	10500	12044			
OUTREACH						
WESTERLY	1.5			1500	1906	1544
WESTERLY	3.0			3000	3406	1544
WESTERLY	4.5			4500	4906	1544

Endeavour Energy

TYPE 3 RAGBOLT FABRICATION

REFERENCE DRAWINGS

056741

DO NOT SCALE

DIMENSIONS IN MILLIMETRES

NUMBER APPROVED ENGINEERING

J. PERERA

15/01/2021

WESTERLY COLUMNS & OUTREACHES

GENERAL DETAIL

A4

353701

A

DRAWN

DATE

CWB

DH

18.12.2011

DH

ORIGINAL SCALE

D. HELE

APPROVED

D. HELE

1:1

1:1

1 2 3 4 5 6 7 8