

TECHNICAL BULLETIN

TB-0068

Street light only identification caps

Background

Instances have occurred where consumer mains were inadvertently connected to a **street light only** circuit, through a terminal block.

Subsequently, two (2) approved sizes (illustrated below) of identification caps have been introduced. The distinctive yellow caps are clearly marked **S/L ONLY**. Vocab numbers are: 1557651 (approval no. UN0207A – to suit a 3-hole terminal block) and 1557669 (approval no. UN0206A – to suit a 6-hole terminal block).

Installation

Caps are to be installed over the **active** terminal blocks, with the writing facing the column door.



Staff who gain work access to streetlight columns should carry stock of both caps on their vehicles. Caps are to be installed retrospectively whilst carrying out work on streetlight columns.

Updated drawings will be available soon for the Underground Distribution Construction Standards Manual, to incorporate these caps. Caps are to be installed during the construction stage once these drawings are released.

Note: Caps are not electrically rated and are to be used for identification purposes only.

For further information:

Adrian George (Distribution Engineering) on 9853 6203 or 0429 000 203.

Contact: Adrian George Ph no: 9853 6203 Date: 15/12/09
Authorised by: Don Wijayasinghe, Distribution Engineering Manager
