


AMENDMENTS	
A	ORIGINAL ISSUE
B	DR'N C.R.T.
	CH'D C.R.T.
	DATE 08-02-96
	JR Nd930208
BCC WAS BBCC.	
C	SED C.H.B.
	DR'N RVL
	CH'D
	DATE 10-10-05
MIDSPAN SEPARATION WAS 150MM MIN. P OF A SEPARATION WAS 300MM MIN.	
D	CDA
	DR'N GSF
	CH'D GSF
	DATE 22-4-09
NOTE 1 ADDED. MIN CLEARANCE INCREASED TO 3M. SIZE WAS A2P.	
E	DSM GSF
	DR'N SM
	CH'D BH
	DATE 25-01-18
CHANGED TERMINOLOGY. REMOVED NOTE 1. CHANGED GROUND CLEARANCE REFERENCE.	
MAM B.Hellyer	



		BCC POLE INSTALLATION (ABC MAINS) 078521	
		BCC POLE INSTALLATION (BARE MAINS) 078518	
REFERENCE DRAWINGS			
DO NOT SCALE DIMENSIONS IN MILLIMETRES		AUTHORISED W. Isley	
DRAWN C.R.T.		MAINS DEVELOPMENT MANAGER 13-02-96	
DATE 29-02-95		A4 078520 E	
CH'D C.R.T.		SHEET No 1 OF 1 SHEETS	

OVERHEAD CONSTRUCTION
COMMUNICATION CABLE INSTALLATION
NEAR SERVICE MAINS