


1. MATERIAL: BAR STEEL FLAT
50 x 10 x 295 LG.
50 x 10 x 440 LG.
2. FINISH: HOT DIP GALVANISED IN
ACCORDANCE WITH AS 1650.
3. VOCAB No. SB19948



VOCAB No. SB19948

AMENDMENTS		ORIGINAL		DO NOT SCALE		REFERENCE DRAWINGS	
A	ORIGINAL	ISSUE		D.B.Britten/JMcQ			
J	R	No.	870375	ASSIST. G.M. ENG.		16/03/89	
B	DR'N	BG		SHEET No		1 OF 1 SHEETS	
	CH'D	GB		PAGE		5-5	
	DATE	01-08-02					
	JR	No					
FILE CONVERTED TO ACAD & 4 HOLES DIA AMENDED FROM Ø18 TO Ø22							
D.S.M.		G. FORD FOR BILL BLEY					
DRAWN		B.G.H					
DATE		16/03/89					
CH'D		ALG					
APPROVED		J.McQuartie					
The drawing and the copyright therein is the property of Endeavour Energy and shall not be copied, reproduced, distributed, loaned or used without the written consent of Endeavour Energy.		Endeavour Energy					
L.V. AERIAL BUNDLED CABLE POLE SUBSTATION STRAIN CLAMP AND DISCONNECTION SWITCH ADAPTOR BRACKET FABRICATION DETAIL							