

AMENDMENTS

A

ORIGINAL
ISSUE

Job No.

WTE14.06

B

DR'N

IJH

CH'D

M.A.

DATE

16/3/12

JOB No

PR 070

DSM

W. LEONG

BRACKET HOLES
RELOCATED 90°

C

DR'N

CP

CH'D

CP

DATE

19/11/2013

JOB No

DSM

M. AZIMI

ITEM 5 WASHER
REMOVED.
DRAWING TITLE 15°
WAS 4°.

D

DESIGN

N/A

DR'N

TV

CH'D

MA/MB

DATE

12.11.25

A.E.M. | S.P.
CONVERTED TO
PORTRAIT VIEW

ITEM	PART	DRG	DESCRIPTION	QTY	REMARK
1	-	-	65x65x5 SHS x 1200 LONG GRADE 350	1	-
2	-	-	65x65x5 SHS x 250 LONG GRADE 350	1	-
3	-	-	65x10 F.B. x 185 LONG AS3679 Gr300	1	-
4	-	-	SLEEVE, 25mm NB STEEL PIPE HEAVY (TO AS1074)	3	-

NOTES:
1. ALL WELD IN ACCORDANCE WITH AS1554-1.
2. BREAK ALL BURNS AND SHARP EDGES.
3. HOT DIP GALVANISE TO AS1559.

DO NOT SCALE
DIMENSIONS
IN MILLIMETRES

AUTHORISED
S.PATON
NETWORK MAINS MANAGER

© This drawing and the copyright therein is the property of Endeavour Energy and may not be copied, reproduced, distributed, loaned or used without the written consent of Endeavour Energy.

ORIGINAL
SCALE
1:10

APPROVED
A. WICKRAMASINGHE

DRAWN
I.S.

DATE
13/03/2012

CH'D
M.A.

OVERHEAD TRANSMISSION
RAISER EARTHWIRE BRACKET DETAIL
MAX 15° LINE DEVIATION

A2P

366177

Rev.
D

SHEET No 1 OF 1 SHEETS