

1

AMENDMENTS

A

ORIGINAL ISSUE

Job No.

WTE14-06

2

NOTES

3

1. POLE STEPS ARE REQUIRED TO BE INSTALLED FROM 8.3m ABOVE GROUND LEVEL. WHERE NORMAL VEHICLE ACCESS IS NOT AVAILABLE (OFF ROAD) POLE STEPS WILL BE REQUIRED FROM 6m ABOVE GROUND LEVEL.

2. MAXIMUM DEVIATION ANGLE APPROXIMATELY 60°, VARIES WITH CONDUCTOR TYPE/TENSION AND ULTIMATE MECHANICAL LOADING ON POST INSULATORS.

4

ITEM	PART/ASSEMBLY NUMBER	DRG Nos.	DESCRIPTION	QTY
1	-	REFER PROJECT	POLE TIMBER	1
2	1018929	015357	POLE STEP	A/R
3	ALS001	398037	INSULATOR ANGLE SUSPENSION ASSEMBLY	3
4	ATP006	054798	M20 EYEBOLT ASSEMBLY	3
5	-	REFER PROJECT	OPGW ASSEMBLY (NOMINAL SHOWN)	1
6	ATP012	054798	INSULATED DOWN LEAD ASSEMBLY	1

5

<