

|                                   |                   |
|-----------------------------------|-------------------|
| AMENDMENTS                        |                   |
| A                                 | ORIGINAL<br>ISSUE |
| Job No.                           |                   |
| B                                 | DR'N DC           |
|                                   | CH'D SD           |
|                                   | DATE 12-12-14     |
| LOGOS AND PHONE<br>NUMBER UPDATED |                   |

# WARNING

## HIGH VOLTAGE CABLES LAID IN THIS LOCATION



Endeavour  
Energy


[www.dialbeforeyoudig.com.au](http://www.dialbeforeyoudig.com.au)  

DIAL 1100  
BEFORE YOU DIG

In an emergency, call  
**131003**, evacuate and  
cordon off the area.

|                                                                        |            |            |
|------------------------------------------------------------------------|------------|------------|
| High voltage cable signs                                               |            |            |
| Type specifications                                                    |            |            |
| <i>All Frutiger or Arial Bold</i>                                      |            |            |
| Type                                                                   | 900w sign  | 600w sign  |
| WARNING                                                                | 216pt caps | 144pt caps |
| HIGH VOLTAGE<br>CABLES LAID IN THIS<br>LOCATION                        | 144pt caps | 96pt caps  |
| In and emergency, call<br>131003, evacuate and<br>cordon off the area. | 144pt u/lc | 96pt u/lc  |

NOTE:  
 MARKER REQUIREMENTS:  
 MARKERS SHALL BE MADE FROM YELLOW  
 COLOUR CLASS 1, RETROREFLECTIVE MATERIAL  
 TO AS 1906, PART 1. (3M TYPE 3871 SERIES OR  
 EQUIVALENT).  
 2 SIZES: 600H x 900W & 450H x 600W.

|                                                                                     |  |                                                   |  |                            |  |                     |  |           |
|-------------------------------------------------------------------------------------|--|---------------------------------------------------|--|----------------------------|--|---------------------|--|-----------|
|  |  | ENDEAVOUR ENERGY                                  |  | ORIGINAL<br>SCALE          |  | APPROVED<br>B.ISLEY |  |           |
| DRAWN KT                                                                            |  | CABLE LOCATION WARNING SIGN<br>FOR RAIL CROSSINGS |  | MANAGER ASSET ENGINEERING. |  | 30.06.06            |  |           |
| DATE 23.06.06                                                                       |  |                                                   |  | A4                         |  | 306255              |  | Rev.<br>B |
| CH'D DM                                                                             |  |                                                   |  | SHEET No 1 OF 1 SHEETS     |  |                     |  |           |