

AMENDMENTS	
A	ORIGINAL ISSUE
B	REDRAWN HV TRENCH EXTENDED
DRN	G.S.F.
CHD	G.S.F.
DATE	26-11-15
DR NO	N/A
NSM	C.Crisafulli

NOTES

- 1) ALL WELDED CONSTRUCTION TO BE IN ACCORDANCE WITH AS1665.
- 2) ITEM 3 TO BE HOT DIP GALVANISED AFTER FABRICATION.
NOTE: THIS ITEM IS REQUIRED ON ALL SIDES OF PENETRATION.
ANGLE IRON TO BE BOLTED AT 400mm CENTRES MAX WHERE POSSIBLE. SEE MOUNTING DETAIL BELOW.
- 3) ALL HV & LV CABLES TO BE HORIZONTAL & LEVEL WITH SUB FLOOR BEFORE ENTERING SUB TO FACILITATE CABLE TERM.
- 4) CONDUITS TO BE SEALED FOR 2HR FIRE RATING WITH OR WITHOUT CABLES INSTALLED

ITEM	QTY	DESCRIPTION	REMARKS
1	2	TREADPLATE ALUM. 6mm x W & L TO SUIT	
2	A/R	BARE ALUMINIUM FLAT 40x6 LEN TO SUIT	
3	A/R	ANGLE STEEL 65x65x6x LEN TO SUIT	NOTE 2
4	A/R	BOLT STEEL HEX HD GALV. M10x35 LG	
5	A/R	NUT UNISTRUT SPRING LOADED P1000 M10	
6	A/R	UNISTRUT CHANNEL P1000CI EZP	
7	2	FLUORECENT FITTING TWIN 40 WATT	
8	3	LOUVRE DOOR 2 STAGE 2mWx2.7mH CLEAR	
9	A/R	CONDUITS 3x125mm + 1x50mm HV TO LV	NOTE 4
10	A/R	TREADPLATE ALUM. 6mm x W & L TO SUIT	

