

AMENDMENTS


A

ORIGINAL
PRINT
ISSUE


DR'N

CH'D

DATE



SIDE VIEW



FRONT VIEW

NOTES

1. STREET LIGHT CONTROL PANEL TO BE WIRED & FITTED BY P.C.C. ON SITE (IF REQ'D.)
2. M.D.I.'s TO BE FITTED BY P.C.C. ON SITE.
3. REFER T.S.I. 155 FOR APPLICATION OF CATEGORY 1 OR 2 DISTRIBUTION PANELS. REFER SHEET 1 FOR CATEGORY 1 COMPACT GENERAL ARRANGEMENT.

17		CABLE TIE 'PANDUIT'	
16	SW11341	WASHER STAINLESS STEEL ROUND FLAT 6	2
15	SNI2491	NUT STAINLESS STEEL HEX M6	2
14	SSI5748	SCREW STAINLESS STEEL CSK HD M6 x 25 LG	2
13	SW10272	WASHER BRASS ROUND FLAT 5	2
12	SW10507	WASHER STEEL ROUND FLAT GALV 10	12
11	SPI7190	PANEL 'GEC' CAT.2 ISOLATORS & 2 FEEDERS	1
10	SFI5908	GEC CAT 2 FUSED FEEDER	2 MAX
9	SSI4652	SETSCREW BRASS RD HD M5 x 20 LG	2
8	SCI7826	PANEL ST. LIGHT CONTROL (AS REQ'D)	1
7	SNI2181	NUT BRASS HEX M5	2
6		NEUTRAL/EARTH BAR	1
5		MDI "WARBURTON FRANKI" TYPE WF73 3 Ø	1
4	STI3278	LINKS 'KLIPPPON' TYPE SAKC 10 C/W 2	4
4	SSI5632	LINKS END SECTION CAT.No 1467/2	1
	SEI0790	LINKS END BRACKET CAT.No 2061/6	2
3		FUSE SINGLE AUX SUPPLIED WITH BOARD	-
2	SBI0827	BOLT STEEL HEX HD GALV M10 x 25 LG	4
1	SBI0819	BOLT STEEL HEX HD GALV M10 x 40 LG	2
ITEM	VOCAB No.	DESCRIPTION	QTY

Endeavour
Energy

SHEET 2 OF 3 SHEETS

ST. LT. CONTROL PNL 1 Ø P.M. SUB MOUNTED FAB.DET	B44200	
STD. CONST PM SUB MV CAT 1&2 PNLS.FRAME FAB.	C16659	
REFERENCE DRAWINGS	DRG. NO.	THIS ISSUE PAGE NO.



ENDEAVOUR ENERGY

ORIGINAL SCALE
NOT TO SCALEP. London
CHIEF ELEC. ENG. DATE 16-2-84ISSUE
IDENTIFICATION

STANDARD CONSTRUCTION PAD MOUNT SUB
MEDIUM VOLTAGE PANELS FRAME
CATEGORY 2- G.E.C. GENERAL ARRANGEMENT

APPROVED	DRAWN	BGK
CH'KD		
CO-ORD.		
D'SERV.		

C 16619

A
INDEX
REFTHIS ISSUE
PAGE NO.

16-2-84