

1. ALL WIRING TO BE 2,5mm² P.V.C. INSULATED
2. ITEM No 3A CØ IS TO BE FITTED WITH A 4A FUSE CARTRIDGE.
3. WHEN STREET LIGHT CONTROL IS REQUIRED ITEM 3B OR 4 IS TO BE BOLTED TO a Ø OR b Ø & FITTED WITH A FUSE CARTRIDGE (RATING TO SUIT LOADING OF STREET SUPPLY).



**Endeavour
Energy**

SHEET 3 OF 3 SHEETS

[illegible]