



G

 ORIGINAL SCALE 1:1	
DRAWN	D.J.Z.
DATE	10-2-93
CH'D	D.J.Z.

1. EARTH TEST STUD (ITEM 1) TO BE THREADED BOTH ENDS AS SHOWN AND ELECTRO-ZINC PLATED.
2. CONDUIT CAP (ITEM 4) AND THREADED INSERT (ITEM 2) TO BE FIXED TO CONDUIT (ITEM 3) AS SHOWN USING A SUITABLE PVC ADHESIVE.
3. EARTH TEST STUD AND SHROUD TO BE SUPPLIED AS A KIT VOCAB NO SS10398.



VOCAB NO SS10398

ITM NO	VOCAB /DRG	DESCRIPTION	QTY	REFER	
1	NA	BAR STEEL ROUND 12 DIA X 175 LG	1	—	
2	NA	ROD PVC ROUND 16 DIA X 12 LG	1	—	
3	NA	CONDUIT PVC RIGID LIGHT DUTY 20 X 110 LG	1	—	
4	NA	CAP PVC CONDUIT 20	1	—	
5	NA	NUT STEEL HEX Z/P M12	2	—	
6	NA	WASHER STEEL FLAT RND Z/P 12	2	—	
7	NA	WASHER STEEL SPRING Z/P 12	1	—	

REFERENCE DRAWINGS		DRG. NO.		THIS ISSUE PAGE NO.	
DO NOT SCALE DIMENSIONS IN MILLIMETRES		J. Allen/JC		ISSUE	
		ASSIST. G.M. ENG.		10-2-93	
		SUB		076449	
		SHEET No 1		OF 1 SHEETS	
				INDEX REF S008A	
				C	
				THIS ISSUE	
				PAGE NO.	

22kV PADMOUNT SUBSTATION
GEC SWITCHGEAR CONNECTIONS
EARTH TEST STUD & SHROUD
FABRICATION DETAIL

SUB

076449

C

ISSUE IDENTIFICATION	
----------------------	--

THIS ISSUE

PAGE NO.